Department of Community Development



3834 Old Buckingham Road, Suite F Powhatan, Virginia 23139

> Tel 804.598.5621 Fax 804-598-5877 www.powhatanva.gov

Certified Mail: 7010 0290 0001 7602 7848

Virginia Electric and Power Company Dominion Virginia Power Attention: Rob Smith 4325 Old Buckingham Rd. Powhatan, VA 23139

RE: Stop Work Order:
Dominion Solar Case# 16-03-ES

Dear Mr. Smith,

An inspection of the above referenced property was on September 28, 2018. Violations from the September 21, 2016 inspection were not corrected as requested. Therefore, the site is in violation of the Virginia Erosion & Sediment Control Law and the Powhatan County Erosion and Sediment Control Ordinance and therefore all land disturbance activity must cease. If you wish to pursue further land disturbing activity, please correct the following actions:

- MS-1 All denuded areas have not been stabilized with temporary or permanent Seed and mulch.
- MS-3 Permanent vegetation is not adequate to stabilize the property.
- MS-19 Properties and waterways downstream of land disturbing activity from erosion and sediment deposition due to peak stormwater runoff.

In accordance with Sec. 62.1-44.15:64 of the Virginia Erosion and Sedimentation Control Law, this letter serves as your NOTICE TO COMPLY/STOP WORK ORDER. This Stop Work Order is in effect for seven days. Extensions may be granted in some circumstances. The corrective measures should be done by Thursday, October 6, 2016. Should these measures not be implemented in accordance with this Stop Work Order by the scheduled inspection, the County Commonwealth's Attorney may be requested to initiate appropriate legal action of state and local laws.

If you have any questions please contact me at 598-5623. Thank you for your prompt attention to this matter.

Sincerely,

Shaun Reynolds Environmental Coordinator